Date Filed: October 23, 2026

Witness: Jared A. Lawrence
Request from: Department of Energy and Environmental Protection

Question:

(AMI) Please provide the breakdown of total AMR meters currently nearing the end of their useful lives in Eversource's Connecticut territory and how many years are remaining in their useful lives?

Response:

Please refer to the petition filed on October 1, 2026 in Docket No. 17-12-03RE02, Exhibit CLP-AMI-3, at page 109, Figure 10 for the requested information.

The majority of the existing Eversource AMR and bridge meter population is nearing the end of its useful life. The Company transitioned from manual meter reading to its current AMR drive-by system in the early 2000s, installing over 600,000 meters between 2000 and 2003. As a result, as shown in Figure 10, by 2029, approximately 600,000 meters, nearly 50% of the Company's meter population, will be over their estimated useful life of 20-years.

Figure 10 – Electric Meter Age Profile

