Conversation #: 1987334
Type: Power Survey
Title #: JB2505862-BRISTOL-ZONE 05

PowerNo	AttacherName	_Billable	ExistingConversationNumber	Comments
12529	CONNECTICUT LIGHT&POWER	Y	Work to accommodate attacher (midspan).	Pull slack in Sec. to poles 23528 & 12530. Clean up drooping streetlight drip loop cable.
12530	CONNECTICUT LIGHT&POWER	Y	Work to accommodate attacher (midspan).	Raise Sec. 6" & pull slack in Sec. to pole 12531. Dress up drooping streetlight drip loop cable with Sec. raise. Inst. zap shield.
12532	CONNECTICUT LIGHT&POWER	Y	Work to accommodate attacher (midspan).	Raise Sec. 22" (6" above bottom of xfrmr). Raise streetlight 12".
10054	CONNECTICUT LIGHT&POWER			No power make ready.
12527	CONNECTICUT LIGHT&POWER			No power make ready.
12528	CONNECTICUT LIGHT&POWER			No power make ready.
12531	CONNECTICUT LIGHT&POWER			No power make ready.
12533	CONNECTICUT LIGHT&POWER			No power make ready.