Date Filed: September 23, 2026

Witness: Lavelle A. Freeman and Juan F. Martinez
Request from: Office of Consumer Counsel

Question:

Refer to Exhibit CLP-TSP-3, at 24. For each year from 2022 through 2026, provide the actual stranded load experienced on the system. For each event, identify the substation, date, stranded MW or MVA, duration, cause, and number of customers whose service could not be restored. If no actual stranded load occurred in a year, please report zero.

Response:

The chart on Exhibit CLP-TSP-3, at 24, refers to a modeled evaluation of the system based on substation load that would not be restored during an N-1 event even after pre-contingent load transfers. In the years identified, there has not been a substation N-1 event that has resulted in stranded load because the substations are designed to handle the event with customers experiencing either no outage or at worst limited to momentary outages during switching or restoration activities. This exhibit highlights, that for the substation in which this risk has been identified it is highly likely that customers will experience an outage related to a transformer failure. The Company's response to information request OCC-603, with an anticipated filing date of September 30, 2026, will provide more detailed information regarding the substation of concern.