Date Filed: October 21, 2026

Witness: Edward A. Davis and Kimberly R. Parsons
Request from: UCONN

Question:

(Distribution Demand Ratchets) For each of Rates 55-58, please state the precise distribution-demand billing formula, look-back period, ratchet percentage, and power-factor measurement used in the existing and proposed tariffs.

Response:

For Rates 55-58, the Distribution Demand is determined via the following, pulled directly from the tariff:

> DETERMINATION OF DISTRIBUTION DEMAND: The distribution demand shall be the highest average 30-minute kilovolt-ampere (kVA) demand in the current month or the preceding eleven (11) months.

This provision is the same in proposed rate schedules. Please refer to UCONN-009, Attachment 1, for the nominal power factors used for Rates 55-58 in converting from kW to kVA if the customer does not have a meter capable of measuring kVA demand.