January 25, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On January 9, 2024, the Company responded to the arrival of a strong low-pressure system. Hazardous winds and strong wind gusts brought on by the storm system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 02:00 a.m., January 10, 2024, the outages peaked when 8,146 customers were experiencing a service outage. In total, the Company estimates that it restored service to 24,625 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

January 29, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On January 13, 2024, the Company responded to the arrival of a strong low-pressure system. Hazardous winds and strong wind gusts brought on by the storm system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 07:00 p.m., January 13, 2024, the outages peaked when 3,360 customers were experiencing a service outage. In total, the Company estimates that it restored service to 7,486 customers for the Friday into Saturday winds. On Sunday, January 14, another weather system roared through late in the afternoon with higher than forecast winds, bringing down trees and tree limbs onto our system. At 4:00 p.m., January 14, 2024 outages peaked again when 14,451 customers were experiencing a service outage. In total, Eversource lineworkers and local contractors had restored service to 30,728 customers over the duration of January 13, 2024 to January 15, 2024. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

February 27, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On February 13, 2024, the Company responded to the arrival of a strong low-pressure system. Hazardous winds and strong wind gusts brought on by the storm system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 12:00 p.m., February 13, 2024, the outages peaked when 3,269 customers were experiencing a service outage. In total, the Company estimates that it restored service to 4,581 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

107 Selden Street, Berlin, CT 06037
P.O. Box 270, Hartford, CT 06141-0270

Vincent P. Pace
Assistant General Counsel

(860) 665-5426
vincent.pace@eversource.com

March 4, 2025

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On February 16, 2025, the Company responded to impacts associated with a strong low-pressure weather system. Wintery mixed precipitation, radial ice, hazardous winds, and strong wind gusts brought on by the strong weather system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 3:00 p.m., February 16, 2025, the outages peaked when 28,738 customers were experiencing a service outage. In total, the Company estimates that it restored service to approximately 133,000 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

March 13, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On February 28, 2024, the Company responded to the arrival of a strong low-pressure system. Hazardous winds and strong wind gusts brought on by the storm system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 02:00 a.m., February 29, 2024, the outages peaked when 9,544 customers were experiencing a service outage. In total, the Company estimates that it restored service to 22,765 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

April 18, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On April 3, 2024, the Company responded to the arrival of a nor'easter. Hazardous winds and strong wind gusts brought on by the storm system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 06:00 a.m., April 4, 2024, the outages peaked when 10,956 customers were experiencing a service outage. In total, the Company estimates that it restored service to approximately 35,000 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

July 22, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On June 26, 2024, the Company responded to impacts associated with severe thunderstorms. Hazardous winds and strong wind gusts brought on by the severe thunderstorms caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 10:00 p.m., June 26, 2024, the outages peaked when 71,506 customers were experiencing a service outage. In total, the Company estimates that it restored service to approximately 115,556 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

July 22, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On June 30, 2024, the Company responded to impacts associated with severe thunderstorms. Hazardous winds and strong wind gusts brought on by the severe thunderstorms caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 2:00 p.m., June 30, 2024, the outages peaked when 10,451 customers were experiencing a service outage. In total, the Company estimates that it restored service to approximately 15,676 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

August 30, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On August 9 and 10, 2024, the Company responded to impacts associated with Post Tropical Cyclone Debby. Hazardous winds and strong wind gusts brought on by the severe thunderstorms caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 5:00 p.m., August 9, 2024, the outages peaked when 13,472 customers were experiencing a service outage. In total, the Company estimates that it restored service to approximately 39,179 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS

107 Selden Street, Berlin, CT 06037
P.O. Box 270, Hartford, CT 06141-0270

Vincent P. Pace
Assistant General Counsel

(860) 665-5426
vincent.pace@eversource.com

December 31, 2024

Mr. Jeffrey R. Gaudiosi
Executive Secretary
Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06050

Re: Docket No. 86-11-18 – DPUC Review of Performance of UI, CL&P and SNETCO in Restoring Service After Storm Carl – Order No. 6 Compliance

Dear Mr. Gaudiosi:

The Connecticut Light and Power Company dba Eversource Energy (the "Company") provides this compliance information pursuant to Order No. 6 in the above captioned docket.

Order No. 6 in the Final Decision provides:

> Commencing from the date of the Decision, May 12, 1987, each of the Companies shall file a Report, including time series details of service restoration, to the Public Utilities Regulatory Authority within 14 days of complete restoral of customer service following the implementation at any level of its respective Emergency Plan.

On December 11, 2024, the Company responded to impacts associated with a strong low-pressure weather system. Hazardous winds and strong wind gusts brought on by the strong weather system caused trees and tree limbs to fail, breaking poles and crossarms, dropping conductors and damaging electrical equipment. At 4:00 p.m., December 11, 2024, the outages peaked when 7,900 customers were experiencing a service outage. In total, the Company estimates that it restored service to approximately 15,000 customers. Final analysis of the storm impact is ongoing.

If you have any questions regarding this submittal, please call Mr. Joseph Godwin, Manager of Emergency Preparedness, at (860) 665-3577 or at (985) 285-9976.

Very truly yours,

Vincent P. Pace
Vincent P. Pace
Assistant General Counsel
On behalf of CL&P d/b/a Eversource Energy

cc: Service List
William Turner, State Emergency Management Director, DEMHS