Date Filed: November 10, 2026

Witness: Jared A. Lawrence and Sean P. Noonan
Request from: Office of Consumer Counsel

Question:

(INTERVAL DATA MANAGEMENT SYSTEM) Please indicate the month and year the Company's current interval data management system was installed and the month and year of any updates.

Response:

The Company uses a combination of field collection applications and a meter data management system to collect and store CT Electric meter data.

There are two field collection applications, FCS, which was implemented in July 2015 and MV90, which was implemented in October 2006. FCS collects AMR and bridge meter data but does not function as a Meter Data Management System (MDMS) within the program's capabilities. MV90 supports TOU meters and is a MDMS, however it is not compatible with AMI meters and lacks the technological advancements to accommodate working with AMI meters.

Field Collection Applications:

- FCS: implemented July 2015
- MV90: implemented October 2006

Meter Data Management:

- MDMS: implemented April 2014

Over the years, numerous enhancements, upgrades and fixes have been implemented to each of these systems to keep the systems running and to meet the Company's service obligations.