PROJECT_NUMBER	PROJECT_DESCRIPTION	Substation	Circuit	DIVISION	DISTRICT	Scope	Total Cost ($k)	Labor Cost ($k)	Outside Services Cost ($k)	Material Cost ($k)	Removals Cost ($k)	Other Cost ($k)	Indirect subtotal ($k)	Contingency ($k)	Study Year	ISD	Maximum Capacity MVA Exceedance	Maximum Capacity AMPS Exceedance	Normal Rating AMPS
CD01543	3R04 Contingency Overload	Rocky Hill 3R	3R04	CENTRAL	HARTFORD	Reconductor	278.4	11.7	94.8	47.5	21.0	1.8	101.6	0.0	2025	6/1/2028	0.08	2	375
CD02199	Oxford 26N7 Contingency Overload	Oxford 26N	26N7	WESTERN	NEWTOWN	Reconductor & Reconfiguration	1,594.0	66.7	542.4	272.1	120.4	0.0	545.2	10.6	2023	6/1/2028	1.10	45	460
CD02587	15U2 Contingency Overload	Chippen Hill 15U	15U2	CENTRAL	CHESHIRE	Reconductor & Reconfiguration	1,450.8	60.7	493.8	247.7	109.6	0.0	529.3	9.6	2024	6/1/2028	0.96	40	421
CD02591	Middle River 28M11 Contingency Overload	Middle River 28M	28M11	WESTERN	NEWTOWN	Reconfiguration	455.4	19.1	155.0	77.8	34.4	0.0	166.1	3.0	2025	6/1/2028	1.80	74	511
CD02660	35A8 Contingency Overload	Wilton 35A	35A8	WESTERN	NORWALK	Reconfiguration	280.2	11.7	95.4	47.8	21.2	1.9	102.2	0.0	2025	6/1/2028	0.22	9	580
CD02651	12N15 Contingency Overload	Ridgefield 22N	22N15	WESTERN	NORWALK	Reconfiguration	352.1	14.7	119.8	60.1	26.6	0.0	128.5	2.3	2025	6/1/2028	0.41	17	235
CD02654	11Y2 Contingency Overload	Flanders 11Y	11Y2	EASTERN	NEW LONDON	Reconductor	695.7	29.1	236.8	118.8	52.6	4.6	253.8	0.0	2025	6/1/2028	3.70	93	490
CD02687	1Q6 Contingency Overload	Uncasville 1Q	1Q6	EASTERN	NEW LONDON	Reconfiguration	146.3	6.1	49.8	25.0	11.1	1.0	53.4	0.0	2025	6/1/2028	0.87	38	395
CD02023	West Brookfield 14H1 Overload	West Brookfield 14H	14H1	WESTERN	NEWTOWN	Reconductor	1,064.0	91.2	120.3	384.0	25.0	0.0	440.0	3.6	2023	6/1/2027	2.10	86	440
CD02087	Noera 13H S/S LCC Load Relief	Noera 13H Todd 30L	30L29	CENTRAL	CHESHIRE	New Feeder	2,952.7	123.6	1,005.0	504.2	223.2	0.0	1,077.2	19.6	2024	6/1/2027	2.00	84	2092
CD02396	West Brookfield 14H S-S Expansion	West Brookfield 14H	14H1	WESTERN	NEWTOWN	Reconfiguration	1,000.0	41.9	340.4	170.7	75.6	0.0	364.8	0.0	2024	6/1/2027			440
CD02570	14W12 Contingency Overload	Rockville 14W	14W12	CENTRAL	TOLLAND	Reconfiguration	129.6	5.4	44.1	22.1	9.8	0.9	47.3	0.0	2024	6/1/2027	2.89	121	440
CD02489	24A17 Normal Overload	Flax Hill 24A	24A17	WESTERN	NORWALK	Reconfiguration	544.9	22.8	185.5	93.0	41.2	0.0	198.8	3.6	2024	6/1/2027	0.38	16	440
CD02469	28F2 Overload	Greenwich 28F	28F2	WESTERN	STAMFORD	Reconductor	1,594.2	285.6	45.6	201.8	38.0	0.0	878.2	0.0	2026	6/1/2027	1.46	64	480
CD02471	11R3 Circuit Overload	Cos Cob 11R	11R3	WESTERN	STAMFORD	Reconfiguration	301.3	12.6	102.5	51.4	22.8	2.0	109.9	0.0	2024	6/1/2027	1.14	50	373
CD02617	28F3 Contingency Overload	Greenwich 28F	28F3	WESTERN	STAMFORD	Reconfiguration	400.3	16.8	136.2	68.3	30.3	2.7	146.0	0.0	2026	6/1/2027	0.20	8	604
CD02739	13S6 Circuit Overload	Darien 13S	13S6	WESTERN	STAMFORD	Reconfiguration	236.0	9.9	80.3	40.3	17.8	0.0	86.1	1.6	2025	6/1/2027	1.10	47	460
CD02903	14M7 Normal Overload	Tracy 14M	14M7	EASTERN	DANIELSON	Reconductor	630.2	45.3	139.3	160.1	50.9	0.0	234.6	0.0	2026	6/1/2027	0.32	8	130
CD02957	Network Unit 354 - Feeder 134 XFMR Replacement	South Meadow 1A	1A134	CENTRAL	HARTFORD	Equipment Replacement	450.9	76.4	56.0	47.8	63.3	0.0	205.9	1.4	2026	6/1/2027	1.12	28	450
CD02958	Network Unit 355 - Feeder 135 XFMR Replacement	South Meadow 1A	1A135	CENTRAL	HARTFORD	Equipment Replacement	498.4	84.5	61.9	52.9	70.0	0.0	227.6	1.5	2026	6/1/2027	1.67	42	450
CD02172	Farmington 1C19 Contingency Overload	Farmington	1C19	CENTRAL	CHESHIRE	Reconductor & Reconfiguration	4,405.1	570.2	390.8	904.0	118.7	27.1	2,394.4	0.0	2023	6/1/2027	3.19	80	490