Date Filed: November 12, 2026

Witness: Amparo Nieto
Request from: Connecticut Industrial Energy Consumers

Question:
Please refer to the ACOS Direct Testimony at page 6, lines 1-10.

a. Please explain how the demand allocators for primary and secondary distribution facilities exclude the loads of customers that take service at primary or transmission voltage from the allocation of facilities at lower voltage levels.
b. Please provide the class NCP demands used for each demand allocator, by voltage level.
c. Please identify the number of Rate 39 customers served at each delivery voltage and the number of Rate 57 customers served at each delivery voltage.

Response:

a. The demand allocators for Primary facilities include the total distribution class NCP corresponding to each class. The demand allocators for the Secondary facilities exclude the portion of the NCP load associated with customers served at Primary; this is approximated using the ratio of secondary customers to total distribution customers in the class. All of the demand allocators refer to NCP of customers that take service at distribution level; no NCP for transmission-connected customers was included.

b. The class NCP demands used for each demand allocator by voltage level are included in Exhibit CLP ACOS-2 Confidential, in tab "*Appendix 1.B Allocator_Input"*. See rows 20 and 21, for allocators "NCP_P" and "NCP_S", respectively.

c. The number of Rate 39 distribution customers is 3, all served at Primary. The number of Rate 57 distribution customers is 72, all served at Primary voltage