Table 1 (prior testing in 1984)

GASOLINE TANK TESTING PROGRAM RESULTS

Location	Tank Size (gal)	Date Tested (1984)	Year Installed	Type of Tank	Type of Protection	No Leak	Dry Line Leak	Wet Line Leak	Tank Leak	Status
Northfield Hydro Station	4,250	12/6/84	1983	Fiberglass	NA			x	x	Tagged out of service-pending work approved by DEQE
Amherst	10,000	12/19/84	1978	Steel	Coal Tar	x				System tight-no leaks
Willimantic Area Work Center	10,000	12/20/84	1974	Steel	NA	x				System tight-no leaks
East Hampton, CT	10,000	9/26/84	1972	Steel	Unknown	x				System tight-no leaks
Area Work Center	10,000	9/26/84	1980	Fiberglass	Unknown			x		Taken out of service-extensive cleaning work