GenConn Energy LLC **Witness: Brandon Shatraw**
Devang Patel

Docket No. 26-06-02

Date Submitted: October 19, 2026

LFE-012 Q:

Provide documentation demonstrating how Company determined the estimated cost of $20,000 for each MTTB in Capital Project 5. (Requested of GenConn)

LFE-012 A:

Please refer to LFE-012 Attachment 1 CONFIDENTIAL, which provides a historical quote from GE indicating a cost for one heat exchanger associated with the MTTB units (2 are required for each turbine unit compartment). This quote was used as a proxy to develop the cost of $20,000. The Company estimated $20,000, which includes estimates of additional materials and installation services that would be necessary. The Company has initiated requests for quotations for these components and services.

The Company expects to provide all the relevant details following procurement processes and actual costs as they are capitalized and included in future revenue requirement requests.