
SW
W
NW
N
210
240
270
300
330
0
273°W (T)
43.430495°, -70.735332° ±4m
92m
SEL
SCHWEITZER ENGINEERING LABORATORIES
SEL-735
POWER QUALITY AND REVENUE METER
Accumulated Energy
09/15/2025
07:34:18
DELIVERED (kWh)
1794.89
RECEIVED (kWh)
5774.62
DELIVERED (kVARh)
7861.27
RECEIVED (kVARh)
1832.39
ACC
RESET
TEST
ENABLED
TEST LED ON
TEST MODE
TEST LED OFF
NORMAL
DISPLAY
ALTERNATE
CAPTURED
WAVEFORM
PO ALARM
RESET
VA ON
VB ON
VC ON
AUX 1
AUX 2
AUX 3
CONFIGURATION
PTR
CTR
FM 9 (4WY)
CL 2/10/20
V 28-277
Hz 60
Solar Generation Meter
Mousam Solar
POI
2025-09-15, 11:34:45 EDT