INT-75899

EVERSOURCE ENERGY

Distributed Energy Resources
107 Selden St.
Berlin, CT. 06037

December 06, 2024

Attention: RIDGEFIELD PUB SCHOOLS

700 N SALEM RD RIDGEFIELD CT 06877

Equipment: 60 kW AC PV installation with one (1) Yaskawa Solectria Solar PVI 60TL-480 three-phase inverters at 480 volts, on a three-phase 277/480-volt service with no energy storage devices (export will be paid underneath LREC / ZREC tariff, located at 750 N SALEM RD RIDGEFIELD CT 06877, RIDGEFIELD PUB SCHOOLS is certified to UL 1741SB & IEEE 1547-2018.

Approval to Energize Revised Date: December 06, 2024

Dear RIDGEFIELD PUB SCHOOLS,

This is a letter for approval to energize of the above stated project to the Eversource system in accordance with the Interconnection Agreement. As stated in the Interconnection Agreement (enclosed) and the "Generator Interconnection Guidelines", the following items must be provided to the Eversource Distributed Resources Group on a regular basis:

1. Annually: Provide a certificate of insurance as described in the enclosed interconnection agreement prior to the insurance expiration date. Please send it to InsuranceCTDG@Eversource.com or to the following address by that date:

   Eversource Distributed Resources
   P.O. Box 1409
   Hartford, CT 06143-1409

2. You are responsible for the periodic maintenance of the relays, interrupting devices, control schemes, and batteries that involve the protection of the EDC's system. Eversource may audit these reports, logs, and other material regarding the interconnection of the Generating Facility at its discretion.

Sincerely,

Gregory M. Pivin

Gregory M. Pivin
Senior Account Executive
Distributed Generation, Eversource Energy
Mobile: (413) – 364 – 7269
E-mail: greg.pivin@eversource.com

cc: Carl Nowiszewski, Manager - Distributed Energy Resources Centrica Business

AEC Solar