Date Filed: March 31, 2026

Witness: Freeman, Lavelle A
Request from: Public Utilities Regulatory Authority

Question:

Att. 5, System Data Requirement No. 9 (Confidential). For each substation identified by Eversource as having load within 90-100% of the normal rating or exceeding the normal rating, provide the following information:

a. A description of any planned or in-progress capital projects at these substations and the status of these projects;
b. The Firm Capacity of the substation;
c. The Load Carrying Capacity (LCC) of the substation;
d. The Distribution System Switching Capacity of the substation;
e. The date on which Eversource first identified the grid need;
f. A copy of the initial funding request forms;
g. If available, a copy of the solution selection forms;
h. If available, a copy of the project authorization forms.

Response:

RSR-003 Attachment 1 CONFIDENTIAL includes a table identifying substations operating at **90–100% of their Load Carrying Capability (LCC)** and provides all requested data items (a through h). Please note that the loading percentage categories referenced in **"System Data Requirement No. 9 (Confidential)"** are based on each substation's **LCC**, rather than its normal rating, as described in the response to **PMEV-017** in Docket No. 25-08-08, Non-Wires Solutions Process Cycle 1.

For substations with **initiated capacity projects** supported by approved documentation, the corresponding files have been included and are referenced within the summary table.

In accordance with Exhibit A of the Final Decision in Docket No. 24-08-08, Non-Wires Solutions Process Initiation Phase, this response containing details regarding System Data Requirement No. 9 (Confidential) is provided confidentially as approved by PURA in that decision.