Date Filed: March 31, 2026

Witness: GLADEY, DAVID L
Request from: Public Utilities Regulatory Authority

Question:

Att. 16, pp. 3-5. For each of the eight reliability related outages on the 14R31 ROW in the last fifteen years, provide the following information:

a. The number of customers that experienced an outage broken out by customer class (residential, commercial, industrial);
b. The total number of outage minutes broken out by customer class;
c. An estimate of the lost load broken out by customer class.

Response:

a.

Event Number	Date	Residential	Commercial	Industrial	Total Customers Affected
1443420	7/22/2010	615	179	0	794
1823854	10/29/2011	N/A*	N/A*	0	3,279
2312364	9/12/2013	2,205	165	0	2,370
3811036	11/22/2018	2,831	234	0	3,065
4327552	8/29/2020	1,200	125	0	1,325
4559922	7/7/2021	1,008	104	0	1,112
5018299	3/14/2023	432	7	0	439
5453436	7/15/2024	2,913	234	0	3,147

* Customer type distinctions are not available in for the 10/29/2011, winter storm Alfred event.

b.

Event Number	Date	Residential Cust Mins	Commercial Cust Mins	Total Cust Mins
1443420	7/22/2010	44,310	12,880	57,190
1823854	10/29/2011	N/A*	N/A*	11,696,193
2312364	9/12/2013	559,998	40,874	600,872
3811036	11/22/2018	127,006	9,662	136,668
4327552	8/29/2020	4,864	1,007	5,871
4559922	7/7/2021	79,632	8,216	87,848
5018299	3/14/2023	177,120	2,870	179,990
5453436	7/15/2024	115,862	9,174	125,036

* Customer type distinctions are not available in for the 10/29/2011, winter storm Alfred event.

c. The estimated load lost by customer class is not available at this level.