Date Filed: March 31, 2026

Witness: GLADEY, DAVID L
Request from: Public Utilities Regulatory Authority

Question:

Att. 16, pp. 3-5. Confirm that the Company analyzed the alternative battery storage solution assuming it would only reduce the load on the circuit during peak load conditions, not provide outage support to customers.

Response:

The alternative battery solution was analyzed to mitigate the contingent overload on the 14R31 while supporting the 11M62 and 11M3 loads.