B-3 If the Facility is **not new construction**: All renovations and/or conversions are required to (i) provide for the installation of EDC meters, or (ii) submit appropriate documentation to the Authority to seek an exemption from this requirement, and such exemption to be granted at the Authority's discretion.

a. **State whether and to what extent the submetering system has been installed as of the date of this Application**. No installation work for the submetering system has begun, but general construction work has commenced.

b. **If the submetering system has not yet been installed, state the date on which installation of the submetering system is anticipated to begin.** Installation of submeters is planned for late 2026/early 2027 pending PURA approval. Submetering of customers will not commence without PURA approval.

c. **Describe how the applicant will provide equipment to allow for the installation of EDC meters should submetering end in the future. In the alternative, submit appropriate documentation with the application to the Authority seeking an exemption from this requirement.** The project will utilize socket type sub meters and will provide electrical meter banks that are on the Eversource CT pre-approved meter list. Should submetering end in the future, the Applicant will seek an Authority exemption at that time.