February 25, 2026

Via FERC E-Filing

Debbie-Anne Reese
Secretary
ATTN: OEP/DHAC
Federal Energy Regulatory Commission
888 First Street N.E.
Washington, DC 20426

Re: Project No. 5261, Newbury Hydroelectric Project, Article 403-2025 Annual Report on Unplanned Deviations.

Dear Secretary Reese:

Green Mountain Power (GMP), owner and licensee for the Newbury Hydroelectric Project (FERC No. 5261) is submitting its 2025 annual report on unplanned deviations from run-of-river operation, bypassed reach minimum flow, and aesthetic spill flow.

Article 403 of the Project FERC license, issued on March 28, 2024, in part requires the following.

> *For unplanned deviations from run-of-river operation, bypassed reach minimum flow, and aesthetic spill flow requirements lasting 3 hours or less that do not result in visible environmental effects, the licensee must file an annual report, by March 1, describing each incident that occurred during the prior January 1 through December 31 time period. The report must include for each 3 hours or less deviation: (1) the cause of the deviation, (2) the duration and magnitude of the deviation, (3) any pertinent operational and/or monitoring data, (4) a timeline of the incident and the licensee's response to each deviation, (5) any comments or correspondence received from the resource agencies, or confirmation that no comments were received from the resource agencies, and (6) a description of measures implemented to prevent similar deviations in the future.*

GMP reviewed the Project operations records to confirm that there were no unplanned deviations at the Project from run-of-river operation, bypassed reach minimum flow, and aesthetic spill flow requirements lasting three hours or less in 2025.

Please contact me at (802) 655-8753, via email at John.Tedesco@greenmountainpower.com, or at the address below, if you have any questions or concerns related to this matter.

Sincerely,



John Tedesco
Generation Project Coordinator
Green Mountain Power Corporation
163 Acorn Lane
Colchester, VT 05446